

Technical data sheet

Z2050QPF-J

• For closed cold and warm water systems

 For switching functions and 2-point controls on the water side of air-handling units and heating systems

• Snap-assembly of the actuator





| Type overview | |
|----------------|----|
| Туре | DN |
| Z2050QPF-J | 15 |
| | |
| Technical data | |

| Functional data | Valve size [mm] | 0.5" [15] | |
|---|--------------------------|---|--|
| | Fluid | chilled or hot water, up to 60% glycol | |
| | Fluid Temp Range (water) | 36212°F [2100°C] | |
| Close-off pressure Δps Differential pressure Δpmax | | 75 psi 40psi | |
| | | | |
| | Angle of rotation note | Operating range 1590° | |
| | Pipe connection | Press fit | |
| | Installation position | upright to horizontal (in relation to the stem) | |
| | Servicing | maintenance-free | |
| | Flow Pattern | 2-way | |
| | Leakage rate | 0% | |
| | Controllable flow range | 75° | |
| | Cv | 5.9 | |
| Materials | Valve body | forged brass | |
| | Stem | brass | |
| | Stem seal | EPDM O-ring | |
| | Seat | PTFE, O-Ring EPDM | |
| | Ball | chrome plated brass | |
| Suitable actuators | Non-Spring | СQВ | |
| | Electrical fail-safe | CQKB(X) | |

Safety notes



WARNING: This product can expose you to lead which is known to the State of California to cause cancer and reproductive harm. For more information go to www.p65warnings.ca.gov
If temperature exceeds 212°F operating range due to a boiler control failure the valve will

safely contain the hot water but manufacturers product warranty becomes invalid. Valve and actuator replacement is at the expense of others.

Product features

ApplicationThe QCV zone valves are suited for large commercial buildings where higher close-off and the
ability to change flow is desired. Common applications include unit ventilators, fan coil units,
VAV reheat coils, fin tube casing, radiant panels and duct coils. The valve fits in space restricted
areas and can be assembled without the use of tools.



| BELIMO | Technical data sheet Z2050QPF-J | | |
|------------------------------------|--|--|--|
| Mode of operation | The ball valve is adjusted by a rotary actuator. The rotary actuator is controlled by an on/off signal or by a commercially available modulating or floating point control system and moves the ball of the ball valve – the throttling device – to the position preset by the control signal. Open the ball valve is carried out counterclockwise and close it clockwise. | | |
| Simple direct mounting | Tool-free snap assembly. The actuator can be plugged on the valve by hand (Caution! Just vertical movements). Pins must match the holes on the flange. | | |
| | The mounting orientation in relation to the valve can be selected in 180° increments. (Possible two times) | | |
| Installation notes | | | |
| Recommended installation positions | The ball valve can be installed upright to horizontal. The ball valve may not be installed in a hanging position, i.e. with the stem pointing downwards. | | |
| | | | |
| Water quality requirements | Belimo valves are regulating devices. For the valves to function correctly in the long term, they must be kept free from particle debris (e.g. welding beads during installation work). The installation of a suitable strainer is recommended. | | |
| Servicing | Ball valves and rotary actuators are maintenance-free. Before any service work on the control element is carried out, it is essential to isolate the rotary actuator from the power supply (by unplugging the electrical cable if necessary). Any pumps in the part of the piping system concerned must also be switched off and the appropriate slide valves closed (allow all components to cool down first if necessary and always reduce the system pressure to ambient pressure level). The system must not be returned to service until the ball valve and the rotary actuator have been correctly reassembled in accordance with the instructions and the pipeline has been refilled by professionally trained personnel. | | |
| Flow direction | Direction of flow in both directions possible. | | |
| | | | |
| Flow setting | set the kvs value (maximum flow rate of the valve). | | |
| | Remove end stop clip and place at desired position. After every change of the flow setting by means of end stop clip, an adaptation must be triggered on the modulating actuators. | | |
| Dimensions | | | |

| Туре | DN | Weight |
|------------|----|--------|
| Z2050QPF-J | 15 | [] |



