

On/Off, Electronic-Fail-safe, 24 V

- Nominal voltage AC/DC 24 V
- Control On/Off







CQKX24



Technical data				
	Electrical data	Nominal voltage	AC/DC 24 V	
		Nominal voltage frequency	50/60 Hz	

AC 19.228.8 V / DC 21.628.8 V
2.5 W
0.5 W
5 VA
22 GA plenum cable, 1 m, 3 m or 5 m, with 1/2" conduit connector
electronic thoughout 090° rotation
actuators are double insulated

	Fur	nction	al d	ata
--	-----	--------	------	-----

Bridging time (PF)	2 s
Pre-charging time	520 s
Angle of rotation	90°
Angle of rotation note	adjustable with mechanical stop
Running Time (Motor)	75 s / 90°
Running time fail-safe	<60 s
Noise level, motor	35 dB(A)
Noise level, fail-safe	35 dB(A)
Position indication	pointer

# Safety data

Weight

Materials

Power source UL	Class 2 Supply
Degree of protection IEC/EN	IP40
Degree of protection NEMA/UL	NEMA 2
Enclosure	UL Enclosure Type 2
Agency Listing	cULus acc. to UL60730-1A/-2-14, CAN/CSA E60730-1:02 CE acc. to 2014/30/EU and 2014/35/EU
Quality Standard	ISO 9001
UL 2043 Compliant	Suitable for use in air plenums per Section 300.22(C) of the NEC and Section 602 of the IMC
Ambient humidity	Max. 95% RH, non-condensing
Ambient temperature	35104°F [240°C]
Storage temperature	-40176°F [-4080°C]
Servicing	maintenance-free
Weight	3.5 lb [1.6 kg]
Housing material	UL94-5VA



## **Product features**

## **Application**

Electrical fail-safe On/Off ZoneTight actuator.


Valve selection should be done in accordance with the flow parameters and system specifications. The actuator is mounted directly to the valve without the need for tools or additional linkage.

The actuator operates in response to AC/DC 24 V.

Angle of rotation is adjustable with the integrated mechanical stop.


## **Electrical installation**

## **INSTALLATION NOTES**





Actuators may also be powered by DC 24 V.



Meets cULus requirements without the need of an electrical ground connection.




# Warning! Live electrical components!

During installation, testing, servicing and troubleshooting of this product, it may be necessary to work with live electrical components. Have a qualified licensed electrician or other individual who has been properly trained in handling live electrical components perform these tasks. Failure to follow all electrical safety precautions when exposed to live electrical components could result in death or serious injury.

# Wiring diagrams

AC 24 V Transformer



Functions	Α	
0% ◀	1	~
100% 🕏	<b>/</b> -	?
Fail Position	100%	Open